

SAS Superstructure

Location: 04-SF-80-13.2 / 13.9 Client Name: CalTrans

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 687 Const Calendar Day: 144 Date: 26-Oct-2012 Friday

Inspector Name: Daouk, Sami Title:

Inspection Type: Continuous

Shift Hours: 07:00 am 05:30 pm **Break**: 00:30 **Over Time**: 02:00

Federal ID: Location:

Reviewer: Schmitt, Alex Approved Date: Status: Submit

Weather

Temperature 7 AM 12 PM 4PM Precipitation Condition

Working Day | If no, explain:

Dispute Dispute

Cable Wrapping Activities

ABF crews came to the site at 6:50 AM. Crews had to work on the South main cable . They had to set the wrapping machine , & wrap the cable . They started at 7:00 AM.

Roger, Carlos, Mario, Michael, Aaron, & Dario had to wrap the South cable wrapping on the main span. Crews had to set the machine on the top of the base plate, fly, set the S wire spools, & connect the air hoses. They started at 7:10 AM. Crews were done at 9:30 AM.

Crews tried to start the 1st wrapping trial at 9:35 AM. when the motor did not start . Crews had to call the technician who came & changed the motor . Crews resumed working on the wire at 9:50 AM. The wires did not lock into each other & over lap each other . Crews had to work on the adjustments from 10:30 AM. to 12:00 PM.

In the afternoon , crews started to wrap the cable between PP # 102 & PP # 100 . Crews wrapped 0.4 meter , weld the wire in 4 locations , remove the 1st few wraps , & push the wrap into the cable band groove . They started at 12 :40 PM. Crews had hard time pushing the cable wrap with the wrapping machine into the groove .. They decided to have slacks in the wire , push the machine upward , & slightly hammer on the wire with plastic covered lumber . until the wrap in the groove . Crews were done at 3:10 PM.

After that , crews had to push the machine down , adjust the wrapping machine , align the wire to fit & lock properly , & start wrapping . They had hard time fitting the wire to lock into each other . They started at 3:30 PM. Crews were done at 4:40 PM. They started to wrap at 4:45 PM. They were done at 4:50 PM. Crews had to wrap up their tools & equipments. They left at 5:00 PM. Crews had wrapped 0.3 meter today

Jesus, Armando, & Jorge had to work on the cable. Crews had to clean the cable using MEK solvent, apply the Zinc coat, work with the other crews on the site. Crews started at 7:15 AM.

In addition to that , crews had to cover the cable between PP # 100 & PP # 102 . They were done at 5:00 PM. Crews left at 5;10 PM.

Froylan , Jose , Pedro , & Carlos had to work on the South main span . Crews had to work on the openings under the cable bands . They had to bring materials to the site , cut to size the wire mesh , overlap & tie with the existing wire mesh . They started at 7:30 AM. Crews were done at 12:00 PM.

04-0120F4 Bid Item: 067 C-SUS-SCC.067 Install Suspender Clamps, Separators, Collars

AMERICAN BRIDGE/FLUOR, A JV

Labor
Trade Class Name RT Hrs OT Hrs DT Hrs Total Remarks Dispute

Contractor: AMERICAN BRIDGE/FLUOR, A JV

Page 1 of 2

Run date 21-Nov-14 Time 11:43 PM

04-0120F4

04-SF-80-13.2/13.9

Self-Anchored

Suspension Bridge

Daily Diary Report by Bid Item

Name: 04-0120F4	Insp	ector Name Daouk, Sami		Dia	ry #: 6	87 Date: 26-Oct-2012 Friday	
Semi-Skilled Laborer	APP	JESUS RUIZ	8.00	2.00	0.00	10.00	
Semi-Skilled Laborer	JNM	JOSE PRADO	5.00	0.00	0.00	5.00	
Semi-Skilled Laborer	JNM	FROYLAN RUIZ-AYALA	5.00	0.00	0.00	5.00	
Semi-Skilled Laborer	JNM	CARLOS MONTEJANO	5.00	0.00	0.00	5.00	
Semi-Skilled Laborer	JNM	CARLOS GARCIA	5.00	0.00	0.00	5.00	
Ironworker	JNM	MICHAEL DRAPER	8.00	2.00	0.00	10.00	
Ironworker	APP	DARIO LUCAS	8.00	2.00	0.00	10.00	
Ironworker	APP	ARRON DAVID	8.00	2.00	0.00	10.00	
Ironworker	JNM	ROGELIO RUIZ	8.00	2.00	0.00	10.00	
Ironworker	APP	MARIO MARQUEZ	8.00	2.00	0.00	10.00	
Ironworker	JNM	CARLOS BUSTAMANTE	8.00	2.00	0.00	10.00	

